

Gillian Marchant
Manager Water & Waste
Tenterfield Shire Council
247 Rouse Street
Tenterfield NSW 2372

Approval number: 17448

Notice of determination

Section 60 approval for UMMWWS Augmentation Project

I am writing to inform you that on Tuesday, 12 March 2024, I, the Director Local Water Utilities, as delegate of the Minister for Water, in accordance with Section 60 (b) of the Local Government Act, has granted approval for your application, for Urbenville, Muli Muli, Woodenbong, Water Supply Scheme Augmentation Project (UMMWSS), Tooloom Falls Road.

The approval is subject to the following conditions:

- Consistency with design - a local water utility can only construct drinking water treatment works that are consistent with those approved, or that it allows for sewage to be discharged, treated, or supplied in a way that is broadly consistent with the way that was approved. Some degree of variation is acceptable to ensure that the practical realities associated with design and construction, or treatment and discharge, are accounted for.
- Consistency with standards - Local water utilities must always adhere to any relevant legal, regulatory, industry or technical standards in completing the works (including environmental planning requirements where relevant).

Scope of approval

- Construction of new clarifier lagoon.
- Re- purposing existing sludge lagoon into a second clarifier lagoon.
- Lagoons designed for an operating period 12 months per lagoon, drying time 12 months per lagoon.
- Moving the location of existing pre-coagulation caustic soda and potassium permanganate dosing points to clarifier lagoons inlet works pit.
- Additional alum dosing point in clarifier lagoons inlet works pit.
- Installation of a polyelectrolyte dosing system.
- Associated pipework and pumps.

The approval operates from 12/03/2024.

Reviews/ appeals

Section 9 of the Regulatory and Assurance Framework for Local Water Utilities outlines the review process for decisions made by the delegated departmental decision maker. Should your council wish to review part or whole of this decision then make contact with the contact officer below.

The department will monitor the conditions attached to your approval.

Your contact officer for this approval is Duncan Harrison, Senior Project Officer (Regulatory Assessments), who can be contacted on email at duncan.harrison@dpie.nsw.gov.au.

Sincerely,

Nicholas Sutton

A handwritten signature in black ink, appearing to read 'N. Sutton', written in a cursive style.

A/Director Local Water Utilities

Department of Climate Change, Energy, the Environment and Water - Water